

Achieving U.S. Safe Drinking Water Standards Using Distillation Desalination

Tory L. Champlin, Jaime Banchs, Mike G. Sweet, and Ezra A. Barkai

Distillation as a desalination technology is not commonly used in the United States for producing potable drinking water. Reverse osmosis (RO), which uses thin film membranes, has been the preferred choice. Distillation has been labeled as more expensive because of the perceived higher usage of energy associated with heating water and higher capital costs.

Today's distillation technologies, which include Multi-Effect Distillation (MED) and Mechanical Vapor Compression (MVC), can be cost-competitive, especially when they are collocated with a power plant or resource-recovery facility such as an incinerator or refinery, where a source of waste steam is available. Thermal technologies can utilize this steam—which would otherwise be lost in the form of stack gases, cooling-water streams, or low-pressure exhaust steam—as a primary or supplemental source of heat for distillation.

This is accomplished, in part, by the use of thermo-compressors and vacuum ejectors. The vacuum ejectors lower the effective temperature needed to achieve boiling from 100°C (212°F) at 1.0 absolute atmosphere to below 70°C (158°F) at 0.34 absolute atmosphere.

The EcoEléctrica Power Plant, located on Puerto Rico's southern coast, is the first facility of its type combining a 507-megawatt power plant, a liquid natural-gas terminal, and a seawater distillation desalination facility—all financed in a single project. The power plant consists of two gas-combustion turbines and one steam turbine. Each produces waste steam, a byproduct that is used by two 3,785 m³/day (1-mgd) MED units to distill seawater from the Caribbean Sea, producing cooling water for a nearby power plant and potable drinking water for EcoEléctrica and the Puerto Rico Aqueduct Sewer Authority (PRASA) for distribution to surrounding communities.

As a commonwealth of the United States, Puerto Rico requires its drinking-water providers to meet all regulations as issued and enforced under the Safe Drinking Water Act (SDWA). Included in these regulations are the Primary Drinking Water Standards, which list limits referred to as Maximum Contaminant Levels (MCLs) for 83 contaminants and specified treatment techniques for nine other contaminants. The U.S. Environmental Protection Agency (EPA) has also established Secondary Drinking

Water Standards and an Unregulated Contaminant List, neither of which are enforced but are provided as goals.

Desalination Plant Description

Figure 1 shows a process diagram of EcoEléctrica's seawater desalination water-treatment plant. The plant includes:

- (1) Intake Structure
- (2) Pretreatment/preconditioning
- (3) Multi-effect distillation (MED) units
- (4) Raw water storage tank
- (5) Remineralization system
- (6) Chlorine disinfection
- (7) Service/fire water storage tank
- (8) Supply pumps

Intake Structure: Seawater is pumped to the desalination plant through an intake structure located approximately 1,000 yards offshore, adjacent to an unloading pier for liquid natural gas. The intake structure is divided into three separate chambers, each provided with a bar screen to remove debris and a submerged centrifugal pump.

Pretreatment/Preconditioning: The seawater is first filtered through two coarse filters to remove medium-to-large solid particles. It is then passed through two ion traps to remove trace amounts of copper and heavy metals that could corrode the aluminum tubes in the distillation units. Inside each ion trap are low-grade aluminum rings that serve as a sacrificial source for corrosion, preventing such corrosion from occurring within the distillation units.

Depending on the water quality, four

Tory L. Champion, Ph.D., P.E., is a senior water process engineer with the Tampa office of Parsons, an engineering consulting firm. Mike G. Sweet, P.E., is vice president of business development for Parsons. Jaime Banchs is operational manager for EcoEléctrica in Pañuelas, Puerto Rico. Ezra Barkai is vice president of North American operations for Ambient Technologies in Plantation.

different chemicals may be added: a disinfectant, a macrofouling inhibitor, a scale inhibitor, and an anti-foam emulsion. A disinfectant is added at the intake structure to minimize the attachment and proliferation of sulfate-reducing bacteria that cause pinhole leaks in the stainless-steel supply lines. A macrofouling inhibitor is also added to control biological fouling. A scale inhibitor is used to minimize the buildup of scale on the heat-transfer tubes. An anti-foam emulsion is added to reduce foaming in the flash chambers caused by high concentrations of certain marine organisms.

Multi-Effect Distillation (MED) Units:

Two distillation units manufactured by IDE Technologies Ltd. of Ra'anana, Israel, are used to distill the pretreated/preconditioned seawater. Each unit is capable of producing 1 million gallons of product water or distillate per day (1-mgd). The units utilize IDE's low-temperature, horizontal-tube, falling-film MED process. Each unit consists of a heat-rejection condenser and four




Figure 1: Process diagram of EcoEléctrica's seawater distillation desalination facility

vaporization/condensation effects.

The seawater is fed into the heat-rejection condenser, where it adsorbs the heat rejected from the fourth effect while being de-aerated. The now-preheated seawater is split into two streams: one discharging to the sea with the brine discharge and the other feeding the distillation unit.

Inside each effect are a series of spray nozzles that distribute the seawater over a bank of heated tubes, vaporizing part of the flow into steam. This steam flows through a series of special demisters to the cooler condensing section of the next effect, where it is condensed into the product water or distillate.

The remaining flow, now slightly more concentrated, is pumped to the second, third, and fourth effects, where the spray-vaporization procedure is repeated to produce additional distillate. From the fourth effect (the hottest effect), however, the remaining flow is discharged as a concentrated brine, which is cascaded through a series of flashing tanks where it is cooled before being returned to the sea. The collected distillate is then discharged and pumped to the post-treatment system.

Because the MED units utilize a vacuum to enhance boiling, the temperature of distillate in each effect is lower than would be expected at atmospheric conditions. Distillate water temperatures in each effect are reported as 57.7, 61.2, 64.7, and 67.7° C (Email communications with Ben Yaish Jacky, IDE Technologies, 2000).

The distillate remains at these temperatures for approximately two minutes before becoming mixed with the distillates from the other effects. Since the flow rates from each of the effects are almost equal, an average temperature for the distillate of 62.8° C can be assumed (Email communications with Ben Yaish Jacky, IDE Technologies, 2000).

Raw-Water Storage Tank: The distillate streams from the second, third, and fourth effects are combined

and pumped into a 250,000-gallon raw-water storage tank. This water supplies the remineralization system, backwash of the remineralization system, and PREPA's South Coast Power Station.

Distillate from the first effect is pumped out separately and discharged to a 100,000-gallon condensate storage tank. This water is polished and stored in a 750,000-gallon demineralized-water storage tank for use as boiler feed water for the power plant.

Remineralization System: The distillate is remineralized by passing it through two limestone filters, adding dissolved calcium carbonate into the water. Sulfuric acid is

injected to lower the pH of the distillate ahead of the limestone filters, enhancing the dissolution of the calcium carbonate. Caustic soda is then injected to neutralize the pH prior to chlorine disinfection with sodium hypochlorite.

Service/Fire Water Storage Tank: The disinfected water is stored in a 400,000-gallon service/fire-water storage tank. A standpipe drain mounted within the tank is used to draw off potable water from the top quarter of the tank, or 100,000 gallons. This water is pumped to EcoEléctrica's service-water and potable-water systems and PRASA. The

Continued on page 39

Table 1: Final Primary Drinking Water Contaminant Standards

Contaminant	Reporting Units	Effective	Maximum Contaminant Level Goal (MCLG)	Maximum Contaminant Level (MCL)	SDWA Compliance Sample (a)	Compliant (yes/no)
Fluoride Rule (b)						
Fluoride	mg/L	Now	4.0	4.0	<0.050	yes
Phase I Rule - Volatile Organics (c)						
Benzene	mg/L	Now	Zero	0.005	<0.00050	yes
Carbon Tetrachloride	mg/L	Now	Zero	0.005	<0.00050	yes
p-dichlorobenzene	mg/L	Now	0.075	0.075	<0.00050	yes
1,2-dichloroethane	mg/L	Now	Zero	0.005	<0.00050	yes
1,1-dichloroethylene	mg/L	Now	0.007	0.007	<0.00050	yes
Trichloroethylene	mg/L	Now	Zero	0.005	<0.00050	yes
1,1,1-trichloroethane	mg/L	Now	0.2	0.2	<0.00050	yes
Vinyl chloride	mg/L	Now	Zero	0.002	<0.00050	yes
Phase II Rule – Inorganics (d)						
Asbestos fibers (>10 µm)	MFL (e)	Now	7	7	<0.20	yes
Barium	µg/L	Now	2000	2000	<10	yes
Cadmium	µg/L	Now	5	5	<1.0	yes
Chromium (total)	µg/L	Now	10	10	<5	yes
Mercury (inorganic)	µg/L	Now	2	2	<0.20	yes
Nitrate	µg/L	Now	10	10	0.11	yes
Nitrite	µg/L	Now	2	2	<0.050	yes
Nitrate + Nitrite	µg/L	Now	10	10	0.11	yes
Selenium	µg/L	Now	50	50	<2.0	yes
Phase II Rule – Organics (d, f)						
Acrylamide	mg/L	Now	Zero	TT (g)	(g)	NA
Alachlor	mg/L	Now	Zero	0.002	<0.0010	yes
Aldicarb	mg/L	Delayed	-	-	<0.0020	NA
Aldicarb sulfone	mg/L	Delayed	-	-	<0.0020	NA
Aldicarb sulfoxide	mg/L	Delayed	-	-	<0.0020	NA
Atazine	mg/L	Remanded	-	-	<0.0015	NA
Carbofuran	mg/L	Now	0.04	0.04	<0.0020	yes
Chlordane	mg/L	Now	Zero	0.002	<0.000020	yes
Chlorobenzene	mg/L	Now	0.1	0.1	<0.00050	yes
2,4-D	mg/L	Now	0.07	0.07	<0.00011	yes
o-Dichlorobenzene	mg/L	Now	0.6	0.6	<0.00050	yes
cis-1,2-dichloroethylene	mg/L	Now	0.07	0.07	<0.00050	yes
trans-1,2-dichloroethylene	mg/L	Now	0.1	0.1	<0.00050	yes
Dibromochloropropane	mg/L	Now	Zero	0.0002	<0.000020	yes
1,2-dichloropropane	mg/L	Now	Zero	0.005	<0.00050	yes
Epichlorohydrin	mg/L	Now	Zero	TT (g,g)	(g)	NA
Ethylbenzene	mg/L	Now	0.7	0.7	<0.00060	yes
Ethylene dibromide	mg/L	Now	Zero	0.00005	<0.000010	yes
Heptachlor	mg/L	Now	Zero	0.0004	<0.000030	yes
Heptachlor epoxide	mg/L	Now	Zero	0.0002	<0.000010	yes
Lindane	mg/L	Now	0.0002	0.0002	<0.000010	yes
Methoxychlor	mg/L	Now	0.04	0.04	<0.000070	yes
Pentachlorophenol	mg/L	Now	Zero	0.001	<0.000044	yes
PCB 1016	mg/L	Now	-	-	<0.00010	NA
PCB 1221	mg/L	Now	-	-	<0.00010	NA
PCB 1232	mg/L	Now	-	-	<0.00010	NA
PCB 1242	mg/L	Now	-	-	<0.00010	NA
PCB 1248	mg/L	Now	-	-	<0.00010	NA
PCB 1254	mg/L	Now	-	-	<0.00010	NA
PCB 1260	mg/L	Now	-	-	<0.00010	NA
PCB Total	mg/L	Now	Zero	0.0005	<0.00010	yes

Distillation

Continued from page 29

remaining 300,000 gallons are used for fire protection at EcoEléctrica.

Governing Standards

To be certified for distribution of potable water in Puerto Rico requires compliance with the SDWA's Primary Drinking Water Standards and standards imposed by Puerto Rico's Department of Health. Table 1 lists the regulated contaminants, their maximum contaminant level goals (MCLGs) and maximum contaminant levels (MCLs), and their reporting units. In addition, all chemicals added must be certified by the American National Standards Institute/National Sanitation Foundation International (ANSI/NSF) Standard 60 for potable water use as required by the Puerto Rico's Department of Health.

Compliance with Maximum Contaminant Levels

Results from one SDWA sample collected after the service/fire-water storage tank, along with an indication of compliance with the primary standards (i.e., yes/no), are listed in the last two columns of Table 1. For the disinfection byproducts listed under Stage 1 of the Disinfectant/Disinfection Byproduct (D/DBP) Rule, seven-day (168-hour) formation potentials with chlorine were performed in the laboratory to ascertain their potential concentrations in the distribution system.

Based on results, the distillation desalination plant complied with all standards listed with an established MCL as currently regulated. For most of the contaminants, analyses indicate levels that are below detection limits. Only for a few, such as nitrate, ethylbenzene, toluene, xylenes, and trihalomethanes, and haloacetic acids, were contami-

nants detected. All were below current MCLs. Measured seven-day (168-hour) trihalomethane and haloacetic acid formation potentials of 0.0045 and 0.0067 mg/L, respectively, were an order of magnitude less than the MCLs required by Stage 1 of the D/DBP Rule of 0.080 and 0.060 mg/L, respectively.

Because of matrix interferences with seawater, influent concentrations could not be measured for the contaminants, making it impossible to assess removals by distillation. Although not listed, total organic carbon (TOC) concentrations were measured at dif-

ferent stages through the facility. Results showed reductions in TOC concentrations from 4.0 mg/L measured in the seawater to 1.2 mg/L after pretreatment/preconditioning to < 1.0 mg/L after distillation.

Compliance with Treatment Techniques

Treatment techniques are listed for contaminants that can not be economically or feasibly measured. These include most of the microbiological contaminants such as viruses

Continued on page 40

Table 1: Final Primary Drinking Water Contaminant Standards (continued)

Contaminant	Reporting Units	Effective	Maximum Contaminant Level Goal (MCLG)	Maximum Contaminant Level (MCL)	SDWA Compliance Sample (a)	Compliant (yes/no)
Phase II Rule - Organics con't. (d, f)						
Styrene	mg/L	Now	0.1	0.1	<0.00050	yes
Tetrachloroethylene	mg/L	Now	Zero	0.005	<0.00050	yes
Toluene	mg/L	Now	1	1	0.0011	yes
Toxaphene	mg/L	Now	Zero	0.003	<0.00018	yes
2,4,5-TP	mg/L	Now	0.05	0.05	<0.00022	yes
Xylenes	mg/L	Now	10	10	0.00093	yes
Phase V Rule - Inorganics (h)						
Antimony	µg/L	Now	6	6	<3.0	yes
Beryllium	µg/L	Now	4	4	<1.0	yes
Cyanide	mg/L	Now	0.2	0.2	<0.0050	yes
Nickel	µg/L	Remanded	-	-	<10	NA
Thallium	µg/L	Now	0.5	2	<1.0	yes
Phase V Rule - Organics (h)						
Adipate (di(2-ethylhexyl))	mg/L	Now	0.4	0.4	<0.0016	yes
Dalapon	mg/L	Now	0.2	0.2	<0.0011	yes
Dichloromethane	mg/L	Now	Zero	0.005	<0.00050	yes
Dinoseb	mg/L	Now	0.007	0.007	<0.00022	yes
Diquat	mg/L	Now	0.02	0.02	<0.00040	yes
Dioxin	mg/L	Now	Zero	30	<1.5855	yes
Endothall	mg/L	Now	0.1	0.1	<0.0090	yes
Endrin	mg/L	Now	0.002	0.002	<0.000020	yes
Glyphosate	mg/L	Now	0.7	0.7	<0.0060	yes
Hexachlorobenzene	mg/L	Now	Zero	0.001	<0.00010	yes
Hexachlorocyclopentadiene	mg/L	Now	0.05	0.05	<0.00010	yes
Oxamyl (vydate)	mg/L	Now	0.2	0.2	<0.002	yes
PAHs (benzo(a)-pyrene)	mg/L	Now	Zero	0.0002	<0.00010	yes
Phthalate (di(2-ethylhexyl))	mg/L	Now	Zero	0.006	<0.0020	yes
Picloram	mg/L	Now	0.5	0.5	<0.00011	yes
Simazine	mg/L	Now	0.004	0.004	<0.0015	yes
1,2,4-Trichlorobenzene	mg/L	Now	0.07	0.07	<0.00050	yes
1,1,2-Trichloroethane	mg/L	Now	0.003	0.005	<0.00050	yes
Lead and Copper Rule (i)						
Lead	µg/L	Now	Zero	TT (j,q)	<1.0	yes
Copper	µg/L	Now	1,300	TT (k,q)	<10	yes
Standards for Radionuclides (l)						
Beta/Photon emitters	pCi/L	Now	Zero	50	<1.0+/-0.5	yes
Alpha emitters	pCi/L	Now	Zero	15	<0.8+/-0.4	yes
Radium 226	pCi/L	Now	Zero	20	<0.3+/-0.2	yes
Radium 228	pCi/L	Now	Zero	20	<0.9+/-0.6	yes
Uranium	µg/L	Now	Zero	30	No data	No data
Standards for Arsenic (m)						
Arsenic	mg/L	Now	-	0.01	<0.0050	yes
Stage 1 Disinfectant/Disinfection By-Product (D/DBP) Rule (n)						
Bromate ion	mg/L	Now	Zero	0.01	< 0.005	yes
Chlorite ion	mg/L	Now	0.8	1.0	<0.010	yes
Total trihalomethanes						
Chloroform	mg/L	Now			0.0013 (o)	NA
Bromoform	mg/L	Now	Zero		<0.00050 (o)	NA
Bromodichloromethane	mg/L	Now	Zero		0.0020 (o)	NA
Dibromochloromethane	mg/L	Now	0.06		0.0012 (o)	yes
Total	mg/L	Now	Zero	0.080	0.0045 (o)	yes

Continued from page 39

and protozoan cysts. Treatment techniques are also required in cases where the analytical method is either not available or not reliable for a particular contaminant.

The Surface Water Treatment Rule (SWTR), Interim Enhanced Surface Water Treatment Rule (IESWTR), and Long-Term 1 Enhanced Surface Water Treatment Rule (LT1ESWTR) were developed to reduce pathogenic contaminants in drinking water. The SWTR requires systems using surface water to disinfect and physically remove and/or inactivate 3-logs (99.9 percent) of Giardia and 4-logs (99.99 percent) of viruses. The IESWTR expanded on the SWTR by requiring systems to physically remove 2-logs (99 percent) of cryptosporidium and included groundwater systems that are determined to be under the direct influence of surface-water contamination.

Relevant to distillation is the requirement to demonstrate by pilot studies or other means that an alternative filtration technology in combination with disinfection can consistently achieve these stated removals and/or inactivation limits. The LT1ESWTR expands on the IESWTR by requiring systems serving less than 10,000 people to comply.

Distillation can remove microbial contaminants by both physical removal and heat sterilization inactivation. Physical removal occurs as a result of the water being evaporated in one chamber and condensed in another. This change in state from a liquid to a vapor and back to a liquid creates a physical barrier preventing microbial contaminants from transmitting from the feed water to the distillate. Rose, et al (1999), demonstrated using a three-stage, multi-effect

Table 1: Final Primary Drinking Water Contaminant Standards (concluded)

Contaminant	Reporting Units	Effective	Maximum Contaminant Level Goal (MCLG)	Maximum Contaminant Level (MCL)	SDWA Compliance Sample (a)	Compliant (yes/no)
Stage 1 Disinfectant/Disinfection By-Product (D/DBP) Rule continued (n)						
Haloacetic Acids						
Monochloroacetic acid	mg/L	Now	Zero		<0.002 (o)	NA
Dichloroacetic acid	mg/L	Now	Zero		0.0032 (o)	NA
Trichloroacetic acid	mg/L	Now	0.03		0.0016 (o)	Yes
Monobromoacetic acid	mg/L	Now	Zero		<0.001 (o)	NA
Dibromoacetic acid	mg/L	Now	Zero		0.0019 (o)	NA
Total	mg/L	Now	Zero	0.060	0.0067 (o)	Yes
Disinfectants						
Chlorine	mg/L Cl ₂	Now	4	4	No data	No data
Chloramines	mg/L Cl ₂	Now	4	4	< 0.50	No data
Chlorine Dioxide	mg/L ClO ₂	Now	0.3	0.8	No data	No data
Total Coliform Rule (p)						
Escherichia coli	NA	Now	Zero		NA	(q)
Fecal coliforms	NA	Now	Zero	TT (r)	NA	(q)
Total coliforms	NA	Now	Zero	(s)	NA	(q)
Surface Water Treatment Rule (t)						
Giardia lamblia	NA	Now	Zero	TT (q)	NA	(q)
Heterotrophic bacteria	Colony/mL	Now	Zero	< 500	NA	(q)
Legionella	NA	Now	Zero	TT (q)	NA	(q)
Viruses	NA	Now	Zero	TT (q)	NA	(q)
Turbidity	NA	Now	Zero	PS (u)	No Data	No Data
Interim and Long Term 1 Enhanced Surface Water Treatment Rule (u)						
Cryptosporidium	NA	Now	Zero	TT (r)	NA	(w)
Profiling and Benchmarking	NA	Now	NA	NA	NA	(x)
Turbidity	NA	Now	Zero	PS (u)	No Data	No Data

- (a) Safe Drinking Water Act (SDWA) Compliance Sample.
- (b) USEPA. "National Primary and Secondary Drinking Water Regulations; Fluoride." Federal Register, 51, 1986: 11396-11412.
- (c) USEPA. "National Primary Drinking Water Regulations; Synthetic Organic Chemicals; Monitoring for Unregulated Contaminants." Federal Register, 52, 1987: 25690-2517.
- (d) USEPA. "Draft Drinking Water Health Criteria Document for Haloacetonitriles, Chloropicrin, and Cyanogen Chloride". Washington D.C.: Criteria and Standards Divisions, Office of Drinking Water, 1991.
- (e) Million of fibers per liter.
- (f) USEPA. "National Primary Drinking Water Regulations: Synthetic Organic chemicals." Federal Register, 56, 1991: 30266-30281.
- (g) An approved analysis method has not been determined or published.
- (h) USEPA "National Primary and Secondary Drinking Water Regulations; Synthetic Organic Chemicals and Inorganic Chemicals; National Primary and Secondary Drinking Water Regulations Implementation." Federal Register, 57, 1992: 31776-31849.
- (i) USEPA. "Maximum Contaminant Level Goals and National Primary Drinking Water Regulations for Lead and Copper." Federal Register, 56, 1991, 26460-26564.
- (j) Action level = 0.015 mg/L.
- (k) Action level = 1.3 mg/L.
- (l) USEPA. "National Primary and Secondary Drinking Water Regulations; Radionuclides: Final Rule." Federal Register, 65, No. 236, 2000: 76708-76753.
- (m) USEPA. "National Primary Drinking Water Regulations; Arsenic and Clarifications to Compliance and New Source Contaminants Monitoring; Final Rule." Federal Register. January 22, 2001, Volume 66, Number 14.
- (n) USEPA. "Microbial and Disinfection Byproduct Rules Simultaneous Compliance Guidance Manual." EPA 815-R-99-011. Office of Water (4607). August 1999.
- (o) Formation potentials measured after reacting with chlorine for 168 hours.
- (p) USEPA. "National Primary and Secondary Drinking Water Regulations; Fluoride." Federal Register, 51, 1989: 22062-22160.
- (q) Compliance discussed later.
- (r) Treatment Technique (TT) required to achieve compliance with regulation.
- (s) No more than 5 percent of the samples per month may be positive. For systems collecting fewer than 40 samples per month, no more than one sample per month may be positive. Every sample that has total coliforms must be analyzed for fecal coliforms. There can not be any fecal coliforms.
- (t) USEPA. "Drinking Water: National Primary Drinking Water Regulations; Filtration, Disinfection; Turbidity, Giardia lamblia, Viruses, Legionella and Heterotrophic Bacteria." Federal Register, 54, 1989: 22062-22160.
- (u) Performance standards.
- (v) USEPA. "Microbial and Disinfection Byproduct Rules Simultaneous Compliance Guidance Manual." EPA 815-R-99-011. Office of Water (4607). August 1999.
- (w) USEPA. "National Primary Drinking Water Regulations: Interim Enhanced Surface Water Treatment Rule; Final Rule." Federal Register, 63, 1998: 69478-69521.
- (x) Systems are required to develop a disinfection profile for Giardia if their distribution system running annual average for either total trihalomethane or five haloacetic acid concentrations is greater or equal to 0.064 mg/L and 0.048 mg/L, respectively. USEPA. "Disinfection Profiling and Benchmarking Guidance Manual." EPA 815-R-99-013. Office of Water (4607). August 1999.

distillation pilot plant, 5-log (99.999 percent) removal of spiked fluorescent beads, similar in size to cryptosporidium.

Heat sterilization, similar to disinfection, inactivates microbial contaminants, making them non-viable. Spiking with live bacteria and viruses in the same pilot plant, Rose, et al (1999), further demonstrated 2.3-logs (99.5 percent) and 5-logs (99.999 percent) physical removal/heat sterilization inactivation, respectively. In a review of microbial contaminants in foods, Rose and Slifko (1999) report work by Fayer showing greater than 3-log (99.9 percent) inactivation by heat sterilization for cryptosporidium in distilled water held at a temperature of 60° C for a period of one minute. For the average temperature of 62.8° C and average time of two minutes reported for the four-stage MED units, greater than 3.0-log (99.9 percent) inactivation by heat sterilization would also be expected.

Based on these reports, it is apparent the combination of physical removal and heat sterilization inactivation provided by the four-stage MED units far exceed the 2-log removal (> 99 percent) of cryptosporidium required by the IESWTR and LTIESWTR. For giardia and viruses, the disinfection contact time provided by the service/fire-water storage tank is more than adequate to achieve 3-log and 4-log inactivation with chlorine, respectively, without any need for physical removal based on EPA criteria (EPA, 1999). Although, as described, distillation has been demonstrated to provide over 5-logs physical removal/heat sterilization inactivation for both giardia and viruses (Rose et al, 1999), combined with the inactivation provided by chlorine disinfection, total log removals as high as 9-logs (99.999999 percent) for giardia and viruses are possible.

Compliance with Secondary Standards

Secondary Drinking Water Contaminant Standards pertain to those contaminants such as taste, odor, and color that may adversely affect the aesthetic quality of the drinking water. **Table 2** lists the Secondary Maximum Contaminant Levels (SMCLs), reporting units, and results from the Safe Drinking Water Compliance Sample, along with an indication of compliance (i.e., yes/no).

SMCLs represent reasonable goals for

Table 2: Secondary Drinking Water Contaminant Standards

Contaminant	Reporting Units	Effective	Maximum Contaminant Level Goal (MCLG)	SDWA Compliance Sample	Compliant (yes/no)
Aluminum	µg/L	Now	5-200	<100	yes
Chloride	mg/L	Now	250	3.2	yes
Color	CU	Now	15	<5.0	yes
Copper	µg/L	Now	1,000	<10	yes
Corrosivity	NA	Now	Non-corrosive	Slightly corrosive	no
Fluoride	mg/L	Now	2	<0.050	yes
Foaming Agents	mg/L	Now	0.5	<0.10	yes
Iron	µg/L	Now	300	<40	yes
Manganese	µg/L	Now	50	<5.0	yes
Odor	TON	Now	3	<1.0	yes
PH	S.U.	Now	6.8-8.5	7.83	yes
Silver	µg/L	Now	100	<10	yes
Sulfate	mg/L	Now	250	65	yes
Total dissolved solids	mg/L	Now	500	180	yes
Zinc	µg/L	Now	5,000	<20	yes

drinking water and are not enforced by the EPA or the Puerto Rico Department of Health; they are intended as guidelines. Based on the one sample collected, the finished-water quality is well below the SMCLs and, in most cases, below detection limits (as indicated by "<"). The water was slightly corrosive, as indicated by negative Langlier and Saturation Indices of -0.21 and -0.21, respectively. Neutral to slightly positive values are more desirable to minimize copper and lead corrosion in downstream piping. More calcium carbonate can be added by the remineralization filters to make the water less corrosive.

Conclusions

EcoEléctrica's distillation desalination facility is capable of providing potable water that complies with the SDWA regulations. The two four-stage MED units are capable of producing exceptionally high-quality water that is below detection limits for most of the contaminants listed. Those few contaminants detected were below current regulated levels. Of particular interest was the effectiveness in reducing natural organic matter (NOM), the precursor in the formation of disinfection byproducts. Samples taken at different stages through the facility showed removals from 4.0 mg/L in the seawater to 1.2 mg/L after pretreatment and < 1.0 mg/L as TOC after distillation. Consequently, disinfection byproduct formation potentials, both THMFPs and HAAFPs, which were also measured after seven days reacting with chlorine, were 0.0045 and 0.0067 mg/L respectively, below Stage 1 D/DBP limits.

References

- AWWA (1999). Water Quality & Treatment, A handbook of Community Water Supplies, Fifth Edition. McGraw-Hill, Inc. New York, New York.
- Electronic mail communications with Ben Yaish Jacky, IDE Technologies, (October 19, 2000) regarding the temperature profile of the distillate in EcoEléctrica's four-stage, multi-effect unit.
- Federal Register (1998). National Primary Drinking Water Regulations: Interim Enhanced Surface Water Treatment Rule, Final Rule. Federal Register/Vol. 63, No. 241/Wednesday, December 16, 1998/Rules and Regulations. p. 69478.
- Pontius, F.W. (2000). "Regulations in 2000 and Beyond." Journal of the American Water Works Association, Vol. 92, No. 3, March 2000, p. 40-54.
- EPA (1998). "Small System Compliance Technology List for the Surface Water Treatment Rule and Total Coliform Rule. EPA 815-R-98-001. Office of Water. September 1998.
- EPA (1999). "Disinfection Profiling and Benchmarking Guidance Manual." EPA 815-R-99-013. Office of Water. August 1999.
- White, G.C. (1999). Handbook of Chlorination and Alternative Disinfectants, Fourth Edition. John Wiley & Sons. New York, New York.
- Rose, J., P. Hauch, D. Friedman, and T. Whalen (1999). "The Boiling Effect: Innovation for Achieving Sustainable Clean Water." Water 21, Magazine of the International Water Association. September-October, 1999,
- Rose, J.B. and T.R. Slifko (1999). "Giardia, Cryptosporidium, and Cyclospora and Their Impact on Foods: A Review". Journal of Food Preparation, Vol. 62, No. 9, 1999. p. 1059-1070.